

2430 "E" Street, N. W.
Washington, D. C.
10 November 1953

25X1A

25X1A9a

[REDACTED]

Dear Mr. [REDACTED]:

25X1A9a

Reference is made to your letter to Mr. [REDACTED],
dated 6 November 1953, same subject.

25X1A9a

1. The sample of aluminum siding described
by you does not quite meet the contract requirement
and does not have some of the advantages in lapping
and maintaining uniform design in appearance as the
type specified and preferred. However, if getting
the specified type involves difficulties which you
consider unjustified, the submitted sample may be
accepted as a minor modification of the contract.

2. The 8"x12" duct referred to should be furred
in as shown on Drawing No. 5-10.

Very truly yours,

[REDACTED]

25X1A9a